

## KEYED NOTES:

- 1 FURNISHED WITH EMERGENCY EQUIPMENT.
- 2 PROVIDE GUIDE PLATE WHEN PULL ROD PENETRATES CEILING.
- 3 VALVE TO BE ACCESSIBLE FOR MAINTENANCE.
- 4 EMERGENCY SIGN(S).
- 5 LOCATE PULL ROD AS CLOSE TO WALL AS POSSIBLE.
- 6 THERMOSTATIC MIXING VALVE IN CABINET W/ DOOR, WALL OR RECESSED MOUNTED.
- 7 LOCATE ISOLATION BALL VALVES (3 REQ'D) WITHIN CABINET.
- (8) TEPID WATER SUPPLY.

DRAWING DEVELOPED FOR ML-3/ML-4 PROJECTS. FOR ML-1/ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN IN-SERTED INTO A DRAWING PACK-AGE).

2	8-14-03	U	EDITORIAL CHANGES & DWG NO. WAS ST6000.							JM	RR	GG	то
1	9-6-02	U	GENERAL REVISION, ADDED PWH PIPING AND MIXING VALVE.						RP	RR	GG	GG	то
NO	DATE	CLASS REV	DESCRIPTION						DWN	DSGN	СНКД	SUB	APP
FACILITY & WASTE OPERATIONS DESIGN ENGINEERING CONSTRUCTION SERVICES													
ENGINEERING STANDARDS MANUAL								DRAWN		R.PEARSON			
								DESIGN		R.ROMERO			
EMERGENCY EQUIPMENT DETAIL, SAFETY SHOWER WITH DRENCH HOSE								CHECKED		G.GREWAL			
BLDG X TA-X								DATE		6-28-99			
SUBMITTED APPROVED FOR RELEASE													
DISCIPLINE POC: GURINDER GREWAL STANDARDS MANAGER: TO													
SHEET												1	
LOS AIAMOS HATIONAL LABORATORY  P  Box 1663 Los Alamos, New Mexico 87545									1	OF	-	5	
	SIFICATION U						LARRY BAYS			DATE			
PROJ	ECT ID			_	DRAWING							RE	
	CHAPTER 6 ST-D2010-1 2												!